



July 05, 2023

KEOSAUQUA WATER WORKS
ATTN MATT DIETZMAN WATER SUPT
BOX 555
KEOSAUQUA IA 52565

SUBJECT: Notice of Violation Monitoring Violation

KEOSAUQUA WATER WORKS (PWSID 8938026) has incurred a monitoring violation per 567 Iowa Administrative Code (IAC) 41 for failure to collect and/or report the following sampling:

Analyte Series	Frequency	Missed Compliance Date	Replacement Sample Due	Next Routine Sample Due
DS 950 DISTRIBUTION SYSTEM				
Total Trihalomethanes (Tthm)	90 Day - Rt	04/30/2023		07/31/2023
Haloacetic Acids (Haa5)	90 Day - Rt	04/30/2023		07/31/2023

The following actions are required to return to compliance:

Public Notice Requirement

Notify the customers served by your water system according to the attached instructions.

Replacement Sampling Requirement

If a replacement sample due date is indicated above; collect a sample by the specified date. Contact your IDNR-certified laboratory for sample containers and mark the sample as a REPLACEMENT (RL).

As a public water supply, you have the responsibility to be aware of the requirements pertaining to sample testing and to take the appropriate action to return compliance. Routine samples must be collected at the frequency specified in your operation permit. Violation of monitoring requirements may result in legal action, including assessment of administrative penalties.

If you believe you have received this letter in error, you should contact your laboratory and notify the IDNR.

For technical assistance related to sampling, please contact Field Office 6 in Washington at 319-653-2135. You may contact me with other questions at 515-725-0339 or E-mail me at chris.spoelstra@dnr.iowa.gov.

Sincerely,

Chris Spoelstra
Digitally signed by Chris Spoelstra
Date: 2023.07.05 13:06:58 -05'00'

Chris Spoelstra
Environmental Specialist, Water Supply Operations Section

cc: [] Field Office 6
[] File PWSID # : 8938026

